



International Conference on Thermoelectrics: Caen, France

# A Study on the Reliability of Thermoelectric Couple Networks

*Christopher Matthes, Chester Everline, David Woerner, Terry Hendricks*

Pre-decisional information for planning and discussion only


© 2018 California Institute of Technology. Government sponsorship acknowledged.



**Jet Propulsion Laboratory**  
California Institute of Technology

# Network Architecture

- The model is based on a thermoelectric couple (TC) network consisting of  $W$  redundant, fully cross-strapped strings (series-parallel circuit) with  $L$  couples per string, as depicted below.
- This model considers only catastrophic failure (due to loss of electrical continuity), and therefore is generally most valid for cantilevered TC designs.




Total # of couples in the network:  $m = W * L$




# Requirements for success

## 1. Electrical continuity



## 2. Sufficient power output



# Generator Reliability Model<sup>[1]</sup>


$$R_G = \sum_{i=0}^j \left[ \binom{m}{i} - F_i \right] R_C^{m-i} [1 - R_C]^i$$

Number of possible  
**arrangements** of  $i$  failures  
in a network of  $m$  couples

Number of possible  
**failure patterns** for  $i$   
failures

$j$  = maximum number of allowable failures  
= (Power output—Power requirement)/(Power per couple)

$R_C$  = couple reliability =  $e^{-\lambda t}$      $\lambda = 1/MTBF$   
 $m$  = total number of couples in network



- ❖ This is a binomial distribution problem, where the reliability is described by the cumulative distribution function, minus the probability of encountering a failure pattern
- ❖ Goal is to assess **generator reliability**  $R_G$  using a defined **couple reliability**  $R_C$  by expressing the probability of having  **$j$  or fewer failures**, without encountering a **failure pattern**
- ❖  $F$  can be determined using a Monte-Carlo analysis, but a closed-form solution of this model was developed and used for the following numerical results



[1] Karr, C. H., "Reliability of Thermoelectric Couple Networks Based Upon Couple Catastrophic Failure," *IEEE Transactions on Reliability*, Vol. R-19, No. 3, August 1970, pp. 116-119.






# Sensitivity study: Network Architecture

- **Reconfiguring** a network containing a defined number of couples into single, two, and three-string cross-strapped architectures affects reliability
- **Voltage** requirement will define constraints on required length of strings
- As # of couples increases, there are more opportunities for **failure patterns** to occur, causing reliability to decrease after a maximum
- Lower couple reliability necessitates more strings to achieve acceptably high generator reliability




**\*Power requirement achieved here with at least 100 operable couples**

$R_G = 0.0059$



# Sensitivity study: Couple Reliability

- Adding couples to the network **increases the margin** between the power output and the requirement, but does not always result in higher overall reliability
- $R_G$  reaches a **peak** and then begins to decrease with additional couples to the network
- Higher  $R_C$ :
  - Results in a higher overall  $R_G$
  - Reaches peak with lower power margin (needs less insurance)
  - $R_G$  declines more slowly after reaching peak (harder to experience a failure pattern)





**\*Power requirement achieved here with at least 100 operable couples**




# Example: Next-Generation RTG

- Each variant is based on the smallest 2 GPHS network, wired in parallel (to maintain consistent voltage)
- 2 GPHS variant has a total of 416 couples (constrained by size)
  - 2 groups of 208 results in 34 V output
  - 4 groups of 104 results in 17 V output
- Voltage can be traded with reliability, or the smallest network can be increased to 4 GPHS size



★ Next-gen RTG design point @ 34V  
(208 groups of 2 = 416 couples)

2 strings of 208 to  
4 strings of 104



★ Alternate design point @17V  
(104 groups of 4 = 416 couples)



# Conclusions

- Distributing couples in a network to a greater number of strings improves reliability
  - Trade between voltage and reliability
  - Relaxes the couple reliability requirement dramatically
- For a series-parallel network, adding couples above minimum requirement to the strings initially increases the reliability to a peak, then gradually lowers the reliability with additional couples
  - Redundancy does not necessarily result in greater reliability (reliability trades with power margin)
- Greater couple reliability results in less penalty in network reliability for each additional couple
- High generator reliability requires either:
  - Very high couple reliability
  - Strategic electrical network configuration







**Jet Propulsion Laboratory**  
California Institute of Technology

---

[jpl.nasa.gov](http://jpl.nasa.gov)

This work was carried out at the Jet Propulsion Laboratory, California Institute of Technology, under a contract to the National Aeronautics and Space Administration.

Backup

# Developing a model: Relevant equations

1. Probability that at least the **minimum number of couples** is operating (*cumulative distribution function*)

- $m$  = # of couples in the network
- $i$  = # of couple failures
- $j$  = maximum # of couple failures to meet power requirement

$$R_P = \sum_{i=0}^j \binom{m}{i} R_C^{m-i} [1 - R_C]^i$$

2. Probability of maintaining **electrical continuity**:

$$R_E = \{1 - [1 - R_C]^L\}^W$$

- **Couple** reliability (survival function):
- **Failure** rate:

$$R_C = e^{-\lambda t}$$

$$\lambda = 1/MTBF$$

- Combining the two requirements for success necessitates an exploration of the **common points** in the sample space

